



City of Aurora

FIELD INSPECTION FORM

Date: 10-10-22

Permit #: NA

Address of Construction: 102 N. McNatt Ave, Aurora MO 65605

Owner/Occupant: Jonathan Hunt Phone #: 417-229-0191

Owner Address : 20512 FR 2012 Crane MO 65633

Contractor: _____ Phone #: _____

Contractor Address: _____

Type of Inspection Performed

- | | | |
|--|--|---|
| <input type="checkbox"/> Plan Review | <input type="checkbox"/> Site Review | <input type="checkbox"/> Set Back Review |
| <input type="checkbox"/> Footing | <input type="checkbox"/> Concrete Floor/Slab | <input type="checkbox"/> Foundation |
| <input type="checkbox"/> Framing | <input type="checkbox"/> Electrical | <input type="checkbox"/> Plumbing |
| <input type="checkbox"/> Mechanical | <input type="checkbox"/> Final/Occupancy | <input type="checkbox"/> Street/Alley |
| <input type="checkbox"/> Sidewalk | <input type="checkbox"/> Demolition | <input checked="" type="checkbox"/> Building Safety |
| <input checked="" type="checkbox"/> Property Violation | <input type="checkbox"/> Floodplain/Flood Damage | <input type="checkbox"/> Storm Drainage |
| <input checked="" type="checkbox"/> General Safety | <input type="checkbox"/> Fire Safety | |
| <input type="checkbox"/> Other: _____ | | |

Notes: Structural collapse, unsafe for entry.

Pass _____ Rejected _____
Carrie Howlett
Building Inspector

Re-Inspect Date _____
10/10/22
Date/Time