

AN ORDINANCE OF THE CITY OF AURORA, MISSOURI AMENDING TITLE V "BUILDING CODE" CHAPTER 520 "FIRE CODE AND PROTECTION" ARTICLE III "FIRE PROTECTION" ADDING SECTION 520.150 "5 INCH STORZ FIRE DEPARTMENT CONNECTIONS" OF THE MUNICIPAL CODE OF ORDINANCES

WHEREAS, the City of Aurora, Missouri (the "City"), is a city of the third class and a political subdivision of the State of Missouri, duly created, organized and existing under and by virtue of the constitution and laws of the State of Missouri, and

WHEREAS, recommendation by the Fire Chief to the Aurora City Council for 5" Storz Fire Department Connections to be installed in accordance with NFPA for the City of Aurora; and

NOW, THEREFORE, BE IT ORDAINED, by the City Council of and for the City of Aurora, Missouri, as follows:

SECTION 1: Title V "Building Code" Chapter 520 "Fire Code and Protection" Article III "Fire Protection" be amended to add Section 520.150 "5 Inch Storz Fire Department Connections" and read as follows:

SECTION 520.150: 5 INCH STORZ FIRE DEPARTMENT CONNECTIONS

Fire Department connection shall be installed in accordance with NFPA Standard applicable to the system design and shall comply with Section 912.2 through 912.7 of the International Fire Code, Edition 2018.

A. Addition – A change to Section 912 Fire Department Connections of the International Fire Code, Edition 2018.

B. Requirements:

1. The location of the fire department connections (FDC) shall provide hose connections that shall not block access to the building or obstruct other fire apparatus from accessing the building.
2. A fire hydrant shall be located within one hundred feet (100') of the FDC. The placement of the FDC must be approved by the Fire Chief.
3. FDC shall have a five-inch (5") Storz connection on a 30-degree downturn.
4. Shall include an approved Storz cap.
5. FDC and other fire protection systems, it shall be the owner to maintain and keep in operation.

C. This includes all new commercial structures where FDC is required for fire protection, for any renovations to commercial structures involving FDC, and for any change of occupancy classification that has an existing FDC connection, if applicable.

*PASSED AND APPROVED BY THE CITY COUNCIL OF THE CITY OF AURORA, MISSOURI
THIS 28th DAY OF MARCH 2023.*

APPROVED:

Jason Lewis, Mayor

ATTEST:

Kamy Kulow, City Clerk