

Chapter 520. Fire Code and Fire Protection

Article II. Fire Code Adoption And Implementation

Section 520.050. Establishment Of Limits Of Districts In Which Storage Of Flammable Or Combustible Liquids In Outside Aboveground Tanks Is Prohibited.

[R.O. 1993 § 520.050; Ord. No. 2010-2862 § 1, 2-9-2010; Ord. No. 2021-3215, 2-9-2021]

The limits referred to in certain Sections of the 2018 International Fire Code are hereby established as follows:

Chapter 55 (limits in which the storage of flammable cryogenic fluids in stationary containers is restricted to): "M-2."

Section 5706.2.4.4 (limits in which the storage of Class I and Class II liquids in aboveground tanks outside of buildings is prohibited): "R-1," "R-2," "R-3," "C-O," "C-1," "C-P," "MHP," "PRD," "CP," "AE."

Section 5706.2.4.4 (limits in which the storage of Class I and Class II liquids in aboveground tanks is prohibited): "R-1," "R-2," "R-3," "C-O," "C-1," "C-P," "MHP," "PRD," "CP," "AE."

Section 61.04.2 (limits in which the storage of liquefied petroleum is restricted to for the protection of heavily populated or congested areas): "A-1," "M-2."